

SUPPLEMENT TO THE MASTER SPECIFICATIONS

Section 1. PURPOSE

The Bedford Regional Water Authority (“Authority”) has adopted a set of Master Specifications in order to ensure consistent installation of water and sewer facilities in Bedford County. In between major revisions to the Master Specifications, it may be necessary for the Authority to modify the materials and methods of construction; this policy is to adopt the new standards until the Master Specifications can be formally modified.

Section 2. METHODS

- A. Existing Utilities: Where new development affects existing water or sewer lines, the same standards as presented in the Master Specifications and below shall apply. Specific improvements necessary to the existing utilities to accommodate the proposed utilities will be addressed on a case by case basis.
 - 1. Interior Drops on Existing Manholes: Where interior drop connections are proposed on existing four (4) foot diameter manholes, only one (1) interior drop connection will be allowed.

Section 3. REVISIONS

- A. This policy was approved and adopted by the Authority’s Executive Director on April 23, 2013, effective July 1, 2013.